

MPA Braunschweig, Beethovenstr. 52, 38106 Braunschweig, Germany

## Certificate of constancy of performance

0761 - CPR - 0857

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product

Powered smoke and heat exhaust ventilator IGW axial ventilator, impeller design TG Range of diameters: 400 mm ... 1,600 mm Class according to EN 13501-4:2007+A1:2009: F<sub>300</sub> 60

produced by or for

Witt & Sohn AG Ziegeleiweg 38 25421 Pinneberg Germany

in the manufacturing plant

Pinneberg (Germany).

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-3:2015

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate comprises an annex with 1 page. It has first been issued on 07-04-2020. It will remain valid till 06-04-2025, as neither the harmonised specification, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.

Braunschweig, 07-04-2020

Z-3/709/03

Dr.-Ing. W. Hinrichs Head of certification

"schwoid,

#### **Smoke Exhaust Ventilator**

#### 1. Use and application classes

oo ana approach oracoo
The ventilator may be mounted as follows:
<ul> <li>☑ outside of the building without thermal insulation</li> <li>☐ outside of the building including thermal insulation</li> <li>☑ inside the building but outside of the fire zone, without thermal insulation</li> <li>☐ inside the building but outside of the fire zone including thermal insulation</li> <li>☑ inside the fire zone without thermal insulation</li> <li>☐ inside the fire zone including thermal insulation</li> </ul>
The motor axle shall be orientated as follows:
<ul> <li>□ horizontal, floor standing</li> <li>□ horizontal, wall mounted</li> <li>□ horizontal, ceiling mounted</li> <li>□ vertical, Δp upward</li> <li>□ vertical, Δp downward</li> <li>□ vertical, wall mounted</li> <li>□ vertical, ceiling mounted</li> </ul>
☐ The ventilator may be used for both functions.
☐ Cooling is necessary.

### 2. Minimum functioning time

In the test the ventilator maintained its function for at least 120 min.

# 3. Technical product data

Hub ratio		P, N, M, X, Y	
Range of diameters		400 mm 1,600 mm	
Direction of flow		unidirectional, reversible	
Motor maker		Nidec	
Motor frame size	min	132	
	max	250	

### 4. Additional information

Standards referred to:

EN 12101-3	EN 13501-4	EN 1363-1	EN 1363-2	ENV 1363-3
			v of performance	