

IMPORTANT INFORMATION  
regarding  
**Fire Testing acc. to EN 12101-3**

- It was our intention to test one of our fans for vertical installation (dia. 2000mm) at *Applus Laboratories (Spain)* located in Spain.

Answer from *Applus Laboratories (Spain)*:

- “What I can offer to you is the following:
  - Up to 3000 mm and 1MW power in horizontal position. The test would be carried out at TST facilities.
  - Up to 1600 mm in vertical position. In that case the test could be carried out either at TST or in Bellaterra.”
- Based on that answer it is not possible to use *Applus Laboratories (Spain)* for vertical heat tests for fans larger than 1600mm.

**CHECK IF THE FANS ARE TESTED IN VERTICAL ORIENTATION  
IF REQUIRED AS PER PROJECT SPECIFICATIONS.**

---